

## GO Switch Models 11 and 21

Model	Contact Form	Sensing Range	Outlet Position	Enclosure Material	Approvals	Wiring Options
<p><input checked="" type="checkbox"/> <b>11</b> 1 1/2" square x 4 9/16" overall. Add 1/2" for bottom conduit outlet</p> <p><input checked="" type="checkbox"/> <b>21</b> 1 1/2" square x 3 13/16" overall. Add 1/2" for bottom conduit outlet</p>	<p><input checked="" type="checkbox"/> <b>1</b> SPDT (Form C)</p> <p><b>3</b> SPDT (Form C) Latching (maintained contact) (Outlet position must be 2, 4 or 5)</p> <p><b>5</b> DMDB, two-circuit, Form Z</p> <p><b>6</b> DMDB, two circuit, Form Z Latching (maintained contact) (Outlet position must be 2, 4 or 5)</p>	<p><input checked="" type="checkbox"/> <b>1</b> Standard sensing - approx. 3/8" side sensing</p> <p><input checked="" type="checkbox"/> <b>2</b> Extended sensing - approx. 9/16" side sensing (Contact Form must be 1 or 3) (Model 11)</p> <p><b>7</b> Precision sensing - approx. 1/4" side sensing (minimal differential)</p>	<p><input checked="" type="checkbox"/> <b>1</b> Behind sensing area</p> <p><b>2</b> Left of sensing area</p> <p><b>3</b> Right of sensing area</p> <p><b>4</b> Same side as sensing area</p> <p><input checked="" type="checkbox"/> <b>5</b> Bottom of enclosure</p>	<p><input checked="" type="checkbox"/> <b>1</b> Brass - coated with flat black lacquer</p> <p><input checked="" type="checkbox"/> <b>2</b> Stainless steel**</p> <p><b>3</b> Brass - corrosion resistant coating (polyurethane)</p> <p><b>4</b> Stainless steel - corrosion resistant coating (polyurethane)**</p> <p>**Stainless steel switches are recommended for wet or harsh environments.</p>	<p><input checked="" type="checkbox"/> <b>0</b> CSA / FM Cl I, Div 2, Grps A-D; Cl II, Div 2, Grps F &amp; G; Cl III Terminal block. (Wiring must be 00) (Lead seal req'd within 18")</p> <p><b>2</b> High temperature to 350°F (Model 11) (Contact form must be 1 or 3; sensing is 1 and enclosure is 2) (Wiring must be F)</p> <p><b>3</b> UL Cl I, Div 1 &amp; 2; Grps A-D; Cl II, Div 1 &amp; 2, Grps E-G; Cl III (Enclosure must be 2 or 4) (Wiring must be A, B, or F) (Lead seal req'd within 18")</p> <p><input checked="" type="checkbox"/> <b>4</b> CSA / FM Cl I, Div 1; Grps A-D; Cl II, Div 1, Grps E-G; Cl III. (Enclosure must be 2 or 4) (Wiring must be A, B, or F) (Lead seal req'd within 18")</p> <p><b>5</b> Mine Safety Health Adm. (MSHA) approved "Explosion Proof", (Enclosure must be 2) (Wiring must be B)</p> <p><input checked="" type="checkbox"/> <b>6</b> CSA / FM Cl I, Div 2; Grps A-D; Cl II, Div 2, Grps E-G; Cl III (Wiring must be A, B, or F) (Lead seal req'd within 18")</p> <p><b>7</b> CSA certified General Purpose</p> <p><input checked="" type="checkbox"/> <b>8</b> UL listed General Purpose</p>	<p><b>Terminal Block</b></p> <p><input checked="" type="checkbox"/> <b>00</b></p> <p><b>Lead Wires</b> - 18 Gauge PVC insulated</p> <p><input checked="" type="checkbox"/> <b>A2</b> 36"</p> <p><b>A3</b> 72"</p> <p><b>A4</b> 144"</p> <p><b>A_ _ _</b></p> <p><b>Cable</b> - 18 Gauge SO rubber insulated</p> <p><b>B2</b> 36"</p> <p><b>B3</b> 72"</p> <p><b>B4</b> 144"</p> <p><b>B_ _ _</b></p> <p><b>Quick Disconnect Mini Connector</b> (Approval must be 7 or 8; 3 pin is 8 only)</p> <p><b>DCA</b> 3 pin</p> <p><b>DCD</b> 4 pin</p> <p><b>DCG</b> 5 pin (See page 18 for cordsets)</p> <p><b>Micro Connector</b> (Approval must be 7 or 8; 3 pin is 8 only)</p> <p><b>DBA</b> 3 pin</p> <p><b>DBD</b> 4 pin</p> <p><b>DBG</b> 5 pin</p> <p><b>SubSea Connector</b> (Approval must be 7 or 8) (Enclosure must be 2 or 4)</p> <p><b>3DD</b> 3 pin</p> <p><b>4DD</b> 4 pin</p> <p><b>3DE</b> 3 pin 90°</p> <p><b>4DE</b> 4 pin 90°</p> <p><b>Hi-Temp Leads</b> (18 Gauge teflon™ insulated)</p> <p><b>F2</b> 36"</p> <p><b>F3</b> 72"</p> <p><b>F4</b> 144"</p> <p><b>F_ _ _</b></p>
<b>Model</b>	<b>Contact Form</b>	<b>Sensing Range</b>	<b>Outlet Position</b>	<b>Enclosure Material</b>	<b>Approvals</b>	<b>Wiring Options</b>

**Ordering Guide**  
Fill in the boxes to create your 'ordering number.'